

Sec. 29-232-60. Fusible plugs

Fire-actuated fusible plugs, if used, shall conform to the requirements of the A.S.M.E. Boiler Construction Code for Power Boilers prescribed in section 29-232-50.

(Effective August 25, 1987)