

Sec. 29-232-86. Nonstandard welded boilers

The maximum allowable working pressure of a nonstandard steel or wrought iron heating boiler of welded construction shall not exceed fifteen psig for steam service or thirty psig for hot water heating service. For hot water supply service the maximum allowable working pressure shall be calculated in accordance with the requirements of section 29-232-81.

(Effective August 25, 1987)