

**Sec. 16-11-113. Frequency**

Alternating current service under normal conditions shall be supplied at sixty cycles per second and under normal conditions the deviation shall not exceed one per cent.