

Sec. 16-11-22. Meter location

(a) Meters may be located inside or outside of a building depending upon local conditions and all meters shall be accessible for reading.

(b) When located inside a building, the meter shall be installed as near as practicable to the point of entrance of the service, be in a clean, dry, safe place and be supported in such a manner as to be as free as possible from damage that will render it unsafe or inaccurate.

(c) When located outside a building, the meter shall be installed as near as practicable to the building and be supported in such a manner as to be as free as possible from damage that will render it unsafe or inaccurate. The gas company shall install an accessible shut-off cock ahead of the meter.