

Sec. 25-128-39d. Fluids used in open-loop geothermal systems

Open-loop geothermal wells shall use only the natural groundwater, and no additives or other fluids are permitted.

(Effective July 8, 2022)