

**Sec. 25-128-49. Well head completion and equipment**

The completion of the well head and the equipment used shall be as follows:

- (a) The top of the casing shall be cut off reasonably smooth and level.
- (b) In the event the well head is enclosed, the enclosure shall be adequately drained. In the event a well pit is used, it shall be constructed in the manner provided by sections 19-13-B51h and 19-13-B51i of the Regulations of Connecticut State Agencies.
- (c) All water piping shall be protected against freezing.
- (d) The well shall be equipped with a tightly fixed vented cap or a sanitary seal with an access port for ventilation. The access port shall have a minimum, inside diameter of one quarter (1/4) inch. It shall be installed and maintained in such a manner as to prevent the entrance of water, dust, insects, or other foreign material, and to permit ready access for the purpose of water level measurement.

(Effective May 21, 1993; Amended July 8, 2022)