

Sec. 16-11-119. Multipliers and test constants

- (a) Meters operating in conjunction with instrument transformers shall have the multiplier plainly marked on the meters or otherwise suitably marked.
- (b) The watthour constant for the meter itself shall be on all watthour meters.