

Sec. 16-11-238. Meter test and record retention

(a) All watt-hour meters installed and owned by a submetering customer shall be tested periodically in conformity with the most recent ANSI Code for Electricity Metering. Meter test data shall be furnished to the Department upon request.

(b) Meter records shall be kept by the submetering customer and shall include the identification of each meter, the date and place of its latest installation or removal and the date and results of the most current meter test. These records shall be maintained for the previous two years.

(c) Every submetering customer shall provide to the Department, upon request data or records as may be deemed necessary by the Department related to the submetering and furnishing of electric service to submetered parties.

(Effective August 21, 1991)