

**Sec. 19-13-B111. Water requirements**

The toilet room shall be provided with an adequate supply of cold and hot or tempered (warm) water. The temperature of the water shall not exceed 115° F (46° C).

(Effective March 27, 1985)