

Sec. 22-336-16. Physical requirements.

(a) Any building to be used as a dog pound shall be constructed in compliance with sections 22-336-14 to 22-336-18, inclusive, of the Regulations of Connecticut State Agencies and maintained in good repair.

(b) The lower portion of interior and exterior walls of a building to be used as a dog pound shall be constructed of concrete or cement block material up to a minimum height of four (4) feet.

(c) All fencing shall be a maximum 1½ inch wire mesh by 11 minimum wire gauge to contain impounded dogs and of a design to prevent injury.

(d) A copy of blueprints detailing the construction of the dog pound facility or renovation of an existing facility shall be submitted to the commissioner at least ninety (90) days prior to the start of construction.

(e) The provisions of this section shall not apply on and after January 1, 2029, or to any dog pound required to conform to the provisions of section 22-336-34 pursuant to subsection (a) of said section.

(Effective April 26, 1993; Amended December 13, 2023)