

**Sec. 25-128-50. Plumbness and alignment of wells**

All gravel packed wells, and all wells equipped with pumps having vertical shafts that require plumbed and aligned walls, shall be tested for plumbness and alignment in accordance with standards of the American Water Works Association.

(Effective September 27, 1978)